

Fire Application #292749 - Why not you foundation

[illegible]



Fire Application #292749 - Why not you foundation

Project Contact

Company Name: Stewart Fire Protection, LLC

Name: Jim Stewart

Email: stewartfire@live.com

Address: 1935 Ludwig Rd.

Phone #: (425) 367-2957

Snohomish WA 98290

Project Type

Nonresidential

Activity Type

Alteration

Scope of Work

Fire Sprinkler Systems

Project Name: Why not you foundation

Description of Work: Add 3 new pendent sprinklers for coverage of new demising wall.

Project Details

System Information

This is a modification or addition to an existing system

Fire System Type

NFPA 13

Alterations

There are alterations to devices or systems.

Quick Response or Recalled Head Change Out

The K-Factor and spacing match existing.

Quick Response or Recalled Head Relocation

No heads are being relocated.

Change of Use

This is not a change of use.

Hydraulic Calculations

There is no change to the hydraulic calculations.

Hazard Classification

The space is classified as Light/Ordinary Hazard.

Mains and Cross Mains

Mains or cross mains are not being relocated.

Heads - Excluding Quick Response and Recalled

1 - 25 total heads

Fire System Counts

Number of Heads Added

3